

ENTHALPY OF MOIST AIR AT SATURATION (SEA LEVEL) (BTU'S PER POUND OF DRY AIR)

Wet Bulb (F)	.0	.1	.2	.3	.4	.5	.6	.7	.8	.9	Wet Bulb (F)
40	15.23	15.28	15.32	15.37	15.42	15.47	15.51	15.56	15.61	15.65	40
41	15.70	15.75	15.80	15.84	15.89	15.94	15.99	16.04	16.08	16.13	41
42	16.17	16.22	16.27	16.32	16.37	16.42	16.46	16.51	16.56	16.61	42
43	16.66	16.71	16.76	16.80	16.85	16.90	16.95	17.00	17.05	17.10	43
44	17.15	17.20	17.25	17.30	17.35	17.40	17.45	17.50	17.55	17.60	44
45	17.65	17.70	17.75	17.80	17.85	17.91	17.96	18.01	18.06	18.11	45
46	18.16	18.21	18.26	18.32	18.37	18.42	18.47	18.52	18.58	18.63	46
47	18.68	18.73	18.79	18.84	18.89	18.95	19.00	19.05	19.10	19.16	47
48	19.21	19.26	19.32	19.37	19.43	19.48	19.53	19.59	19.64	19.70	48
49	19.75	19.81	19.86	19.92	19.97	20.03	20.08	20.14	20.19	20.25	49
50	20.30	20.36	20.41	20.47	20.53	20.58	20.64	20.69	20.75	20.81	50
51	20.86	20.92	20.98	21.03	21.09	21.15	21.21	21.26	21.32	21.38	51
52	21.44	21.49	21.55	21.61	21.67	21.73	21.78	21.84	21.90	21.96	52
53	22.02	22.08	22.14	22.20	22.26	22.32	22.38	22.44	22.50	22.56	53
54	22.62	22.68	22.74	22.80	22.86	22.92	22.98	23.04	23.10	23.16	54
55	23.22	23.28	23.34	23.41	23.47	23.53	23.59	23.65	23.72	23.78	55
56	23.84	23.90	23.97	24.03	24.10	24.16	24.22	24.29	24.35	24.42	56
57	24.48	24.54	24.61	24.67	24.74	24.80	24.86	24.93	24.99	25.06	57
58	25.12	25.19	25.25	25.32	25.38	25.45	25.52	25.58	25.65	25.71	58
59	25.78	25.85	25.92	25.98	26.05	26.12	26.19	26.26	26.32	26.39	59
60	26.46	26.53	26.60	26.67	26.74	26.81	26.87	26.94	27.01	27.08	60
61	27.15	27.22	27.29	27.36	27.43	27.50	27.57	27.64	27.70	27.78	61
62	27.85	27.92	27.99	28.07	28.14	28.21	28.28	28.35	28.43	28.50	62
63	28.57	28.64	28.72	28.79	28.87	28.94	29.01	29.09	29.16	29.24	63
64	29.31	29.39	29.46	29.54	29.61	29.62	29.76	29.83	29.91	29.98	64
65	30.06	30.14	30.21	30.29	30.37	30.45	30.52	30.60	30.68	30.75	65
66	30.83	30.91	30.99	31.07	31.15	31.23	31.30	31.38	31.46	31.54	66
67	31.62	31.70	31.78	31.86	31.94	32.02	32.10	32.18	32.26	32.34	67
68	32.42	32.50	32.59	32.67	32.75	32.84	32.92	33.00	33.08	33.17	68
69	33.25	33.33	33.42	33.50	33.59	33.67	33.75	33.84	33.92	34.01	69
70	34.09	34.18	34.26	34.35	34.43	34.52	34.61	34.69	34.78	34.86	70
71	34.95	35.04	35.13	35.21	35.30	35.39	35.48	35.57	35.65	35.74	71
72	35.83	35.92	36.01	36.10	36.19	36.28	36.38	36.47	36.56	36.65	72
73	36.74	36.83	36.92	37.02	37.11	37.20	37.29	37.38	37.48	37.57	73
74	37.66	37.76	37.85	37.95	38.04	38.14	38.23	38.33	38.42	38.51	74
75	38.61	38.71	38.80	38.90	39.00	39.09	39.19	39.28	39.38	39.47	75
76	39.57	39.67	39.77	39.87	39.97	40.07	40.17	40.27	40.37	40.47	76
77	40.57	40.67	40.77	40.87	40.97	41.08	41.18	41.28	41.38	41.48	77
78	41.58	41.68	41.79	41.89	42.00	42.10	42.20	42.31	42.41	42.52	78
79	42.62	42.73	42.83	42.94	43.05	43.15	43.26	43.37	43.48	43.58	79
80	43.69	43.80	43.91	44.02	44.13	44.24	44.34	44.45	44.56	44.67	80
81	44.78	44.89	45.00	45.11	45.23	45.34	45.45	45.56	45.67	45.79	81
82	45.90	46.01	46.13	46.24	46.36	46.48	46.59	46.70	46.81	46.93	82
83	47.04	47.16	47.28	47.39	47.51	47.63	47.75	47.87	47.98	48.10	83
84	48.22	48.34	48.46	48.58	48.70	48.82	48.95	49.07	49.19	49.31	84
85	49.43	49.55	49.68	49.80	49.92	50.04	50.17	50.29	50.41	50.54	85
Wet Bulb (F)	.0	.1	.2	.3	.4	.5	.6	.7	.8	.9	Wet Bulb (F)

(Total Heat = CFM X 4.5 X Enthalpy Change)